

SEPARATION DISTANCES FOR WASTE STABILIZATION PONDS

| <u>AREA</u> | <u>COUNTIES</u> | | | |
|--|------------------|----------------|---------------|---------------|
| | <u>ELLSWORTH</u> | <u>LINCOLN</u> | <u>OTTAWA</u> | <u>SALINE</u> |
| House it serves | 100' | 100' | 100' | 100' |
| Other residential structures | 250' | 250' | 250' | 250' |
| Applicant's private water supply well | 50' | 50' | 50' | 50' |
| Property lines, including right-of-way | 100' | 100' | 100' | 100' |
| Public water supply well | 100' | 200' | 100' | 100' |
| Public water transmission lines | 25' | 25' | 25' | 25' |
| Water table | 4' | 4' | 4' | 4' |